

CERTIFICATE OF CONFORMANCE

Part Number:

Model Number:

W3T17304

IP-LXM30HI-3

Serial Number: 2183871

Date Tested: 3/29/2018

The above stated Model/Part Number is certified to have been manufactured and tested in accordance with our ISO 9001 Management System and all the requirements specified in Evoqua Water Technologies LLC Manufacturing Work Instruction MFG-010.

AP	PLICABLE TEST PROCEDURE	ACCEPTANCE CRITERIA	PASSED TEST
1)	Pressure Test (MFG-048/007)	100 psi for≥ 0.25 hours - Leak Free	
2)	Rinse up Test (MFG-048/007)	10MOhm-cm in \leq 12 hours	
3)	Electrical Resistance test (MF088ST)	≤ 50 ohms	
4)	Polarity/ wiring inspection (MF088ST)	Verify connections	

APPLICABLE STANDARDS	<u>CONFORMS</u>
1) Asbestos, Lead Free, and RoHS Compliant per 2011/65/EU directive	✓
2) Wetted Materials- FDA requirements for food contact applications (21 CFR)	
3) EN 60204-1 Safety of Machinery - Electrical Equipment of machines Part 1: General Requirements	
4) Low Voltage Directive (LVD) 2014/35/EC	
5) This model has also been certified HALAL	
6) Spacer Material - NSF/ANSI 51-2015 for food equipment material	
7) Spacer Material - NSF/ANSI 61-2015 for drinking water system components - Health Effects	
8) Spacer Material - NSF/ANSI 14-2015 for plastic piping system components and related material	
9) Spacer Material - ISO 10993 (parts 5, 10, 11 and 18) - Biological evaluation of medical devices	\checkmark

The manual for the above component can be found on: www.ionpure.com Should you need further assistance, please E-mail: ionpure@evoqua.com We value you as our customer and will accommodate you in whatever way to provide total satisfaction. Sincerely,

aball Maria

Rahoul Bhagat - ISO QA Mgmt. Rep. Evoqua Water Technologies LLC - Ionpure Products